

# VOC Content Test Certificate

Monday, January 24<sup>th</sup>, 2011

Manufacturer: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills, NSW, 2147)

Sample Description: AF748 Linoleum Adhesive

Tested: December 2010

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</b>	<b>AF748</b>
Sub-Floor Adhesive 50 grams per Litre as VOC content material	<b>7 grams per Litre as VOC content material</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>AF748</b>
Sub-Floor Adhesive 50 grams per Litre as VOC content material	<b>7 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1012-06