

VOC Content Test Certificate

Tuesday April 17th, 2007

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Ardex WPM 001 waterproofing membrane

Production Date: March 2007

Date Tested: April 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star IEQ-13	Ardex WPM 001
Architectural Sealant 250 grams per Litre	18 grams per Litre



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant