

# VOC Content Test Certificate

Tuesday October 2<sup>nd</sup>, 2007

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Ardex WPM 300 water-based epoxy membrane

Date Tested: September 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Ardex WPM 300</b>
Architectural Sealant 250 grams per Litre maximum	<b>26 grams per Litre</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**Project F0709-11**